

Akce:	Plzeň, ul. Sušická
Sonda č.:	DP1
Datum provedení:	16.3.2021
Zkoušku provedl:	M.Volše, A. Kačora

Hloubka [m]	Počet úderů	Dynam. odpor [MPa]	Moment	Počet úderů snížený o krouťící moment pro q = 30 kg	Počet úderů snížený o krouťící moment pro q = 50 kg
0	0	0.00	0	0	0
0.1	0.5	0.49	5	0.3	0
0.2	1.5	1.49	5	1.3	1
0.3	4	4.00	5	3.8	2
0.4	5	5.00	5	4.8	3
0.5	3	3.00	5	2.8	2
0.6	12	12.01	5	11.8	7
0.7	8	8.00	5	7.8	4
0.8	6	6.00	5	5.8	3
0.9	5	5.00	5	4.8	3
1	6	5.29	5	5.8	3
1.1	5	4.41	5	4.8	3
1.2	7	6.17	5	6.8	4
1.3	10	8.82	5	9.8	5
1.4	13	11.47	5	12.8	7
1.5	7	6.17	5	6.8	4
1.6	7	6.17	5	6.8	4
1.7	17	15.00	5	16.8	9
1.8	14	12.36	5	13.8	8
1.9	29	25.60	5	28.8	16
2	23	18.16	35	21.6	12
2.1	52	41.06	35	50.6	28
2.2	48	37.90	35	46.6	26
2.3	29	22.90	30	27.8	16
2.4	35	27.64	25	34	19
2.5	42	33.16	15	41.4	23
2.6	38	30.01	15	37.4	21
2.7	51	40.27	15	50.4	28
2.8	46	36.32	15	45.4	25
2.9	39	30.80	15	38.4	22
3	63	45.00	15	62.4	35
3.1	39	27.86	15	38.4	22
3.2	74	52.86	15	73.4	41
3.3	57	40.71	15	56.4	32
3.4	31	22.14	15	30.4	17
3.5	51	36.43	15	50.4	28
3.6	47	33.57	15	46.4	26
3.7	65	46.43	15	64.4	36
3.8	74	52.86	15	73.4	41
3.9	45	32.14	15	44.4	25
4	36	23.47	15	35.4	20
4.1	32	20.86	15	31.4	18
4.2	29	18.91	20	28.2	16
4.3	78	50.86	20	77.2	43
4.4	92	59.99	35	90.6	51
4.5	125	81.51	50	123	69

