

Technical drawing of a double-door metal safe. The drawing shows a front view of the safe with two doors. The total width is 840 mm, divided into two sections of 290 mm and 550 mm. The height is 240 mm. The safe is labeled with 'RE' on the left and 'R1' on the right. The doors are numbered 1 and 2. The safe is shown with a lock mechanism on the right door. The safe is mounted on a base with a height of 50 mm. The base is labeled 'cca 50'. The safe is shown with a cross-section of the base and a label 'TERÉN' indicating the ground level.

- Hloubka sestavy: 240mm  
Stupeň mechan. ochrany: IK10



- Elektrická přípojka bude realizována 3-fázová.

- Stávající odběrné místo je jiženo jističem 3x24,7A. Tato hodnota bude změněna na 3x20A a tarif změněn na C62. nutno požádat ČEZ prostřednictvím Odboru energetiky a služeb (kontaktní osoba Ing. Jaroslav Michalík).

- Před opravou je nutné požádat ČEZ o novou SoP – přemístění měření prostřednictvím Odboru energetiky a služeb (kontaktní osoba Ing. Jaroslav Michalík).

	12/2019	PO PŘIPOMÍNKOVÉM ŘÍZENÍ
--	---------	-------------------------

SŽDC, státní organizace, Dlážděná 1003/7, 110 00 Praha 1  
Oblastní ředitelství Olomouc, Nerudova 1, 779 00 Olomouc



Oprava silnoproudých zařízení OŘ Olomouc

SO 29 Oprava osvětlení zast. Odrlice

## Přehledové schéma napájení

Archivní číslo:  
1906084\_01\_5039\_0

Formát:	Datu
4x4	00/2

Stupeň PD:	Cás
DSP	F 3