

## EXPLANATION OF THE COMPETITION TERMS AND CONDITIONS NO. 24

Správa železnic, státní organizace, with its registered office at Dlážděná 1003/7, Prague 1, Postcode 110 00, Czech Republic, ID No.: 709 94 234 (the "**Contracting Authority**"), commenced a procurement procedure regarding the design competition entitled "**Správa železnic Headquarters**", published in the Tenders Electronic Journal under registration no. Z2020-034118 (the "**Competition**"). The Competition has been announced as an open design competition pursuant to Section 145 of Act No. 134/2016 Sb., on Public Procurement, as amended (the "**PPA**").

The Contracting Authority has received a written request for explanation of the Competition Terms and Conditions pursuant to Section 144(2) of the PPA from a prospective participant interested in participating in the Competition. The Contracting Authority hereby provides an explanation of the Competition Terms and Conditions in both Czech and English languages including the exact wording of the request for explanation of the Competition Terms and Conditions, without identification details of the prospective participant who has requested the explanation.

	<b><i>Request of the participant where the explanation was provided based on a request for explanation</i></b>	<b><i>Explanation of the Contracting Authority</i></b>
<b>1.</b>	<p><i>Translation of the request:</i></p> <p>Can you please tell us the altitude of the upper edge of the metro tube in the position of the building B-B cross-section (p. 16 of the "Regulation" Annex)? What is the minimum distance of the structure above the metro tube if it is to be structurally independent? Can we get a longitudinal cross-section of metro tubes in the area of the territory concerned?</p>	<p>For the purpose of the Competition, please refer to the heights in the cross sections provided. Documentation detailing the metro tubes will be provided in the stage of finalising the competition entry.</p> <p>The distance between the structure and the metro tube depends on the specific technical design but new structures may not burden the existing structure of the metro tube. In general, a distance of at least 2 metres is recommended.</p>
<b>2.</b>	<p><i>Translation of the request:</i></p> <p>Can we adjust the transport solution of the public road at the level of sector A in our design so as to have the tramway located between the two directions of the road for cars?</p>	<p>The Nádražní Street profile design is based on the approved project of its reconstruction; therefore, the proposed arrangement of the street including the tramway should be respected, as it is not the Contracting Authority's investment but the City of Prague's investment.</p>

**For the avoidance of any doubts, the Contracting Authority states that the provision of explanations above does not constitute a change in the Competition Terms and Conditions within the meaning of Sections 98(5) and 99 of the Public Procurement Act.**

**The Contracting Authority would like to point out to the supplier (prospective participants) that pursuant to clause 5.3.1. of the Competition Terms and**

**Conditions, they may submit requests for explanation of the Competition Terms and Conditions only in writing, no later than 17 days before the lapse of the deadline for the submission of a competition entry, i.e. by 25 January 2021 12:00 p.m.**

The Contracting Authority recommends suppliers who have any requests for explanation to make use of the above period and submit the requests to the Contracting Authority on time. After the expiry of the deadline, the Contracting Authority will not be accepting any requests for explanations of the Competition Terms and Conditions submitted by suppliers.

**The Contracting Authority reminds that the current time limit for submitting competition entries has been set until 12 February 2021, 5:00 p.m. CET (Central European Time).**

**Prague, 25 January 2021**